



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

www.rivcoeh.org

SUPPLEMENTAL REPORT TO SAN. FORM # CO# 0069878

DATE 7/22/19

SUBJECT BurgerIM

PERMIT NO. PR0075232

ADDRESS 13394 Limonite Ave #110 Eastvale

DISTRICT 55

INSPECTOR J. Van Stockum / J. Smith

REMARKS: Response to complaint (CO# 0069878) received 7/22/19. Complaint states facility does not have hot water. At time of arrival, facility employees were aware no hot water is available. The facility was observed to be open and actively prepping food. Employee stated facility has not had hot water since 7/19/19 (3 days). Immediately cease all food preparation. Further legal action will be taken if the facility operates without hot water. (NOTE: Water temperature was measured at a maximum 86°F and dropping.)

Facility was also observed to be using Ammonia cleaner in place of an approved sanitizer solution. Discontinue this practice immediately. This facility is not to resume operations. No other sanitizer was observed on site.

Observed the hot water faucet handle of the warewash sink. Replace this handle immediately. (NOTE: Hot water is stuck in the "on" position, being controlled by the sprayer faucet valve.)

This facility has been closed by this Department due to inadequate hot water, lack of sanitizer solution, and broken hot water faucet handle at the warewash station. Once repairs have been completed, hot water (minimum 120°F) is available at all sinks, approved sanitizer solution is on site (with approved test strips), the hot water faucet handle has been replaced, all dishes and utensils have been properly cleaned (washed, rinsed, and sanitized), and all contaminated food has been discarded, contact this Department at (951) 273-9140 to request a reopening inspection. "Facility Closed" sign was posted; do not remove.

NOTE: No food operations are to be conducted until a representative of this Department verifies the above have been corrected. This includes, but is not limited to, food preparation, warewashing, hand washing, etc.

RECEIVED BY: [Signature]



County of Riverside

DEPARTMENT OF ENVIRONMENTAL HEALTH

For general information call: 1-888-722-4234

www.rivcoeh.org

FACILITY NAME BurgerIm					DATE 7/23/2019	TIME IN 12:45 PM	TIME OUT 1:15 PM
LOCATION 13394 Limonite Ave #110, Eastvale, CA 92880						RE-INSPECTION DATE Next Routine	
PERMIT HOLDER Southern California Franchise Ventures LLC					E-MAIL Not Specified		
PERMIT # PR0075232	EXPIRATION DATE 06/30/2019	SERVICE Reopen Closed Facility	FACILITY PHONE (949)874-9996	PE 3620	DISTRICT 0055	INSPECTOR NAME Roshanak Wood	

Inspector Observations:

Re inspection to reopen a previously closed facility due to no hot water. Hot water has been restored to > 120F at all sinks. Hot water faucet was also fixed properly. Closure sign is removed and violation abated.

Eastvale@burgerim.com

Signature

Abdul Bidiwi
Person in Charge
07/23/2019

Roshanak Wood
Environmental Health Specialist
07/23/2019